

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-0751:001 Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Safe-Air, 1855 S. 54th, Cicero IL 60804
Contact: *Lee Stack (708) 652-9100

DESIGN: Models 150, Type A, B, C, D and XM interlocking blade type fire dampers.
Refer to listee's data sheet for detailed product description and operational considerations.
The sizes of dampers are as follow:

<u>Single Section</u>		<u>Multiple Section</u>		<u>Mounting Position</u>
Width	Height	Width	Height	
48"	48"	120"	48"	Horizontal
60"	60"	120"	80"	Vertical

RATING: 1-1/2 Hrs.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances
and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL Listed as 12-hour fire-rated dampers. Suitable for vertical and horizontal installations.

NOTE: Leakage rating not evaluated. Refer to Category 3230 for listed leakage dampers.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager